



HVAC SPS 327 SUBCHAPTER III



SUBCHAPTER IV — HEATING, VENTILATING, AND AIR CONDITIONING



SPS 327 HVAC VS. SPS 323

- SPS 327 **Subchapter III HVAC** closely follows SPS 323
- SPS 327 is for seasonal overnight use in camping units 400 square feet or less in campgrounds only!
- 400 Square feet will limit the size of furnaces





WHAT SPS 327 HVAC CODE INCLUDES

- SPS 327.39 Design.
- SPS 327.40 Selection of equipment.
- SPS 327.41 Types and location of equipment.
- SPS 327.42 Combustion air.
- SPS 327.43 Mechanical draft systems.
- SPS 327.44 Equipment maintenance information.

WHAT SPS 327 HVAC CODE INCLUDES

- **SPS 327.45** **Ductwork.**
- **SPS 327.46** **Dampers, registers, and grilles.**
- **SPS 327.47** **Piping.**
- **SPS 327.48** **Venting system location.**
- **SPS 327.49** **Multiple appliance venting.**
- **SPS 327.50** **Fuel storage.**



WHAT SPS 327 HVAC CODE DOES NOT INCLUDE

- Habitable rooms
- Clearance from combustibles
- Unvented furnaces & space heaters, vented wall furnaces, conversion burners for furnaces, heat pump appliances, boilers, water heaters used for space heating, location
- Solid-fuel-burning appliances, Safety controls
- Interlocking of Dampers and Simultaneous Operation
- Air Distribution Systems
- Smoke detectors in & insulating exterior walls under-floor space
- Exterior Ducts, Underground Ducts, Duct Construction, Duct Support, Joints and Seams, Vibration Control, Air Passageways of Envelops Dwellings
- Masonry chimneys, Factory-built chimneys
- Chimney connectors, smoke pipes and stovepipe
- Condensate drains
- Equipment Location and Operation

WHAT'S NEW?

- **SPS 327.41(5)(b)** A tankless water heater may be installed in any closet or cabinet. The tankless water heater shall be installed in accordance with the manufacturer's installation instructions.





Thank you!

For any questions please email:
DSPSSBUDCTech@wisconsin.gov